



Government of Karnataka  
Health and Family Department  
Community Health centre, Kampli


**SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

No. Sa.Aa.Ke.kampli/02/2024-25

Dated: 15/04/2024

It is certified that an inspection team headed by Dr. Ravindra Kanakeri, Administrative Medical Officer from Community Health Centre, Kampli PHED inspected the SRI VIDYASAGARA HIGHER PRIMARY SCHOOL, 21st ward Ballari road, Kampli on 12/04/2024 and on the basis of Water Test Report (Attached) bearing no TC1270700000024F dated 06/04/2024 of District water quality testing lab, Ballari (PHED Lab) certified that the SRI VIDYASAGARA HIGHER PRIMARY SCHOOL has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid for a period of 1 year from the date of issue

  
Administrative Medical Officer,  
Community Health Centre, Kampli

To  
Principal,  
Sri Vidyasagara Higher Primary School,  
21st ward Ballari road, Kampli

  
**SECRETARY**

Sri Navabharatha Vidyavardhaka Sangha(R)  
(Sri Vidyasagara Higher Primary School)  
Vinayaka Nagara, 5th Cross,  
KAMPLI-583132. Ballari (Dist)

  
**PRINCIPAL**

Sri Vidyasagara Higher Primary School  
(Sri Navabharatha Vidyavardhaka Sangha(R))  
21st Ward, Ballari Road,  
KAMPLI-583132. Ballari (Dist)

**RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK**

District water quality testing laboratory Ballari

O/o Executive Engineer, Rural Drinking water supply &amp; sanitation Division

e-mail: eerdwsd.bly@gmail.com

TC-12707

**TEST REPORT**

To,  
The Principal  
Sri Vidyasagara Higher Primary School  
Ballari Road 21<sup>st</sup> ward  
Kampli-583132.  
Ballari (Dist)

Report date: 06-04-2024  
ULR No: TC1270700000024F  
Report Number: 2400024  
Reference: Sample Submitted by customer  
Sample Receipt Date: 06-04-2024  
Sample Code: RDWSBLY24APR00024  
Date of sample collection: 06-04-2024  
Analysis start date: 06-04-2024  
Analysis completion date: 06-04-2024  
Sample collection protocol: RDWSD/WQMSP/SOP/23  
Sample quantity: 1 Ltr

Sample Particulars: Drinking Water

Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012	Permissible Limit IS 10500 : 2012	Protocol
<b>Description:</b>					
1.	pH Value @Temp 25°C	7.42	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2.	Specific Conductance, µS/cm @ 25°C	290	–	–	IS 3025 (Part-14) : 2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6) : 2018
4.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-08) : 2023
5.	Colour, Hazen Units	5	5	15	IS 3025 (Part-4) : 2021
6.	Turbidity, NTU	0.0	1	5	IS 3025 (Part-10) : 2023
7.	Total Dissolved Solids @ 180°C, mg/l	166	500	2000	IS 3025 (Part-16) : 2023
8.	Alkalinity as CaCO <sub>3</sub> , mg/l	28	200	600	IS 3025 (Part-23) : 2023
9.	Total Hardness as CaCO <sub>3</sub> , mg/l	20.01	200	600	IS 3025 (Part-21) : 2009
10.	Calcium as Ca, mg/l	2.40	75	200	IS 3025 (Part-40) : 1991
11.	Magnesium as Mg, mg/l	3.40	30	100	IS 3025 (Part-46) : 2023
12.	Chloride as Cl, mg/l	13.9	250	1000	IS 3025 (Part-32) : 1988
13.	Sulphate as SO <sub>4</sub> , mg/l	2.77	200	400	IS 3025 (Part-24) : 2022
14.	Fluoride as F, mg/l	0.10	1	1.5	APHA 23 <sup>rd</sup> Edition: 4500F-D
15.	Nitrate as NO <sub>3</sub> , mg/l	4.13	45	No relaxation	APHA 23 <sup>rd</sup> Edition: 4500NO <sub>3</sub> -B
16.	Iron as Fe, mg/l	0.014	1	No relaxation	IS 3025 (Part-53) : 2003 Method A

Remark: The above tested sample meet the permissible limit as per IS 10500:2012 RA 2018 Drinking water specification hence the source of sample shall be used for drinking purpose.

Analysed by:   
Analyst: Jadeppa M

Authorized Signatory:

Technical Manager: Bheemaraja CT

RDWSD/WQMSP/TeR/O1

Note:

- 1) The sample drawn by the laboratory.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.

\*\*\*\*\*END OF THE TEST REPORT\*\*\*\*\*

**SECRETARY**

Sri Navabharatha Vidyavardhaka Sangha(R)  
(Sri Vidyasagara Higher Primary School)  
Vinayaka Nagara, 5th Cross,  
KAMPLI-583132. Ballari (Dist)

**PRINCIPAL**

Sri Vidyasagara Higher Primary School  
(Sri Navabharatha Vidyavardhaka Sangha(R))  
21st Ward, Ballari Road,  
KAMPLI-583132. Ballari (Dist)