

C.No:171/DFO/Ballari/CC/2026-27

**Office of the District Fire Officer
Karnataka State Fire and Emergency Service
Ballari District, Ballari - 583 104.
Date 18/08/2026**

To,
The Secretary
Sri Navabharatha Vidya Vardhaka Sangha(R)
Vinayaka Nagara. 5th Cross, 6th Ward
Kampli. Kampli (Tq) Ballari(Dist),

Sub: Issue of "**Compliance Certificate**" to "Sri Vidyasagara Higher Primary School" Dise No: 29120512102 Located at 21st Ward, Behind Kalika Temple, Kampli, Kampli Taluk, Ballari District

Ref: 01)C.No:158/DFO/BLY/FAC/2026-27, Date: 13-08-2026 "Fire Advice Certificate" Issued by District Fire Officer, Ballari District Ballari
02) Applicant Letter Dated: 10-08-2026
03)C.No:170/DFO/Ballari/2026-27 Date: 18-08-2026 Inspection Report.

With reference to the subject cited above, As per reference (1) "Sri Vidyasagara Higher Primary School" Dise No: 29120512102 Located at 21st Ward, Behind Kalika Temple, Kampli, Kampli Taluk, Ballari District Was inspected by District Fire Officer, Ballari District Ballari had from the fire Prevention, fire fighting and evacuation point of view & Fire Advice Certificate was issued by District Fire Officer, Ballari District Ballari to the above said institute for firefighting system to be installed within 03 Months including training Part.

As per reference (2) Applicant Requested to Issue the Compliance Certificate. Hence The District Fire Officer, Ballari District, Ballari was Inspected the Educational Building on Dated: 18-08-2026 & Submit the Report As per reference (3) that the applicant has Maintained all the recommendation and checked, found the fire fighting systems are working in good condition during inspection & Recommended to Issue the compliance certificate for the same.

Hence here with issuing the "**Compliance Certificate**" for your above said Educational Building from fire prevention, fire fighting and evacuation point of view & recommended to maintain the same in good working condition at any time. And 04 Employees are Trained at our R.A Mundkur Fire And Emergency Academy, Bengaluru, Therefore at-least 40% of staffs/ employees should be trained in basic fire fighting at our R.A Mundkur Fire & Emergency Academy, Bannerghatta Road, Bengaluru

This Compliance certificate is valid for 12-08-2027 and it is renewable.

Your's Faithfully,

[Signature] 18/08/26

**District Fire Officer
Karnataka State Fire and Emergency Service
Ballari District, Ballari.**

SECRETARY

**Sri Navabharatha Vidyavardhaka Sangha(R)
Vidyasagara Higher Primary School)
Vinayaka Nagara, 5th Cross,
KAMPLI-583132. Ballari (Dist)**

PRINCIPAL

**Sri Vidyasagara Higher Primary School
(Sri Navabharatha Vidyavardhaka Sangha(R))
21st Ward, Ballari Road,
KAMPLI-583132. Ballari (Dist)**

C.No: 158/DFO/Ballari/FSR/2026-27

Office of the District Fire Officer
Karnataka State Fire and Emergency Service
Ballari District, Ballari - 583 104.
Date 13/08/2026

ANNEXURE-I

Group B, Educational Buildings

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.

To,

The Secretary

Sri Navabharatha Vidya Vardhaka Sangha(R)
Vinayaka Nagara. 5th Cross, 6th Ward
Kampli. Kampli (Tq) Ballari (Dist)

Sub: Recommended to Issue of "Fire Advice Certificate" to "Sri Vidyasagara Higher Primary School" Dise No: 29120512102 Located at 21st Ward, Behind Kalika Temple, Kampli, Kampli Taluk, Ballari District.
Ref : Applicant Letter Dated on: 10-08-2026

With reference-01 to the subject above cited, the premises of "Sri Vidyasagara Higher Primary School" Dise No: 29120512102 Located at 21st Ward, Behind Kalika Temple. Kampli, Kampli Taluk, Ballari District was inspected by Me Dated on 12-08-2026 with respect to fire prevention, fire fighting and evacuation measures to be complied premises and Submitted building details as under.

A. Details of the Building/Premises:-

01.	Name and Address of the applicant.	: The Secretary Sri Navabharatha Vidya Vardhaka Sangha(R) Vinayaka Nagara. 5 th Cross, 6 th Ward Kampli. Kampli (Tq) Ballari(Dist)
02.	Name and Address of the premises.	: "Sri Vidyasagara Higher Primary School" Dise No: 29120512102 Kampli, Kampli Taluk, Ballari District 21 st Ward, Behind Kalika Temple. Kampli.Kampli (Tq) Ballari(Dist)
03.	Name and Address of the Building owner.	: Sri P.Nageshwara Rao, Sri T.Kotresh, Smt. P.Rohini. Sri Navabharatha Vidya Vardhaka Sangha(R) Vinayaka Nagara. 3 rd Cross, 6 th Ward Kampli, Kampli (Tq) Ballari (Dist)

1 | Page

PRINCIPAL

Sri Vidyasagara Higher Primary School
(Sri Navabharatha Vidyavardhaka Sangha(R))
21st Ward, Ballari Road,
KAMPLI-583132. Ballari (Dist)

SECRETARY

Sri Navabharatha Vidyavardhaka Sangha(R)
(Sri Vidyasagara Higher Primary School)
Vinayaka Nagara, 5th Cross,
KAMPLI-583132. Ballari (Dist)

04.	Number of Buildings	:	04 No's Building			
05.	Number of floors	:	<u>Block-01:</u> Ground + 1 Upper floor. <u>Block-02:</u> Ground Floor. <u>Block-03:</u> Ground + 1 Upper floor. <u>Block-04:</u> Ground + 1 Upper floor.			
06	Floor-wise details of occupancy :-					
		:	<u>Block-01</u> Ground + 1 Upper floor.			
	Ground Floor	:	Class Room-10 No's Office Room-02 No's Toilet Room-02 No.			
	1 st Floor	:	Staff Room- 01 No. Office Room- 01 No. Principal Room- 01 No. Cabin- 01 No. Hall- 01 No.			
		:	<u>Block-02 Ground Floor</u>			
	Ground Floor:	:	Lab Room- 03 No's Library- 01 No. Record Room- 01 No. Class Room- 05 No's Toilet Room- 02 No's			
		:	<u>Block-03 Ground + 1 Upper floor.</u>			
	Ground Floor:	:	Class Room-04 No's			
	1 st Floor	:	Class Room-04 No's			
		:	<u>Block-04 Ground + 1 Upper floor.</u>			
	Ground Floor:	:	Guest Room- 01 No Library- 01 No.			
	1 st Floor	:	Class Room-04 No's			
07	Height of the building	:	08.00 Mtrs	04.00 Mtrs.	08.20 Mtrs	08.00 Mtrs
08	Site area	:	8191.68 Sq.Mtr.			
09	Built-up area of each floor :-	:	<u>Block-01</u>	<u>Block-02</u>	<u>Block-03</u>	<u>Block-04</u>
	Ground Floor	:	1179.27 Sq Mtrs	144.00 Sq Mtr	280.34 Sq Mtrs	280.34 Sq Mtrs
	1 st Floor	:	1179.27 Sq Mtrs	--	280.34 Sq Mtrs	280.34 Sq Mtrs
10	Total built-up area	:	2358.54 Sq Mtrs	144.00 Sq Mtrs.	560.68 Sq Mtrs	560.68 Sq Mtrs

11	Surrounding properties:-		
	East :	Open Land.	
	West :	Open Land.	
	North :	09 Mtr Wide Connecting Road.	
	South :	Open Land.	
12.	Set back area available around the Building:-		
	East :	10.00 Mtrs.	Recommended: To provide as per Local Zonal Regulations.
	West :	02.30 Mtrs.	
	North :	04.50 Mtrs.	
	South :	03.40 mtrs.	

B. On inspection of this Educational premises, the following fire prevention, fire fighting and evacuation measures are recommended & are considered absolutely essential from fire safety point of view:-

Sl. No. [01]	Details [02]	Existing [03]		Recommendations [04]				
01	Accessibility to Premises.	The premises is accessible from 09 Mtrs wide Annapurna Rice Mill Opposite Road at North Side.		-				
02	No of entrances.	01 No.		-				
03	No. of staircases available	No of staircase	:	<u>Block-01</u> (01 No)	<u>Block-02</u> (01 No)	<u>Block-03</u> (01 No)	<u>Block-03</u> (01 No)	--
		Width of staircase	:	01.70 Mtr.	01.00 Mtr	00.90 Mtr	00.90 Mtr	
		Width of treads	:	30 Cms.	30 Gms	28 Cms	28 Cms	
		Height of risers	:	15 Cms.	15 Cms	15 Cms	15 Cms	
		No of riser per flight	:	11 risers	15 risers	15 risers	15 risers	
		Height of handrails	:	01.00 Mtrs.	01.00 Mtrs.	00.90 Mtrs	00.90 Mtrs	
04	Fire extinguisher	Provided 01 No ABC Fire Extinguisher each of 6 kg capacity Should be Located As Available Within 15 Mtrs Radius. in each floor & each Block.			Recommended To Provide 01) 01 No of CO2 Fire Extinguisher of 4.5 kg capacity Should be Provided near Electrical Panel Board And Electrical Room.			

			[All the extinguishers suggested above should be with B.I.S. markings and should be located at an easily accessible position without obstructing the normal passage and maintained periodically].
05	Escape routes	Provided Signage board is required with illuminated points for in which direction to go outside from the building for staff & students and also separate light arrangement to the illumination board by doing from battery operated at Block-01, 02, 03 & 04	Adequate
06	Fire order (Fire Safety Plans)	Provided The Notice board is Displayed by the employees in case of any emergency displayed with the telephone number of Kurugodu Fire Station i.e- 08393-263301 & 112, and the telephone number of nearest Ambulance services and Police Station.	Adequate
07	No Smoking Board	Provided COTPA Sec-4 Direction No Smoking area Smoking her is an offence Board Should be written in English & Kannada both language is Permanently displayed at inside the Entry/Exist of Each Floor.	Adequate
08	Fire Siren	Not Installed	A fire Siren shall be installed in the premises to inform the inmates in case of a fire emergency and evacuate the area.
09	Nominate one fire Nodal officer	Not Nominated	A fire nodal officer shall be nominated either from teaching or no teaching staff.

12	Fire fighting training.	03 Persons got 02 days Basic fire fighting Training at Regional Fire office, Kalaburagi Fire Station as on Date: 21/11/2022 to 22/11/2022. 01) Sri.Narasappa 2022 12 3140 02) Sri. Veeresh 2022 12 3139 03) Sri. Doddabasappa 2022 12 3138	Adequate
----	-------------------------	--	----------

13) Fire Precautionary Measures:

- 1) Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical cum panel premises.
- 2) Accumulation of combustible waste in and around the premises should be avoided.
- 3) The exit ways shall be always kept clear without any Obstruction.
- 4) Liquefied petroleum gas should not be stored in the building.
- 5) The doors shall not be kept locked / latched during working hours and shall be free from obstruction.
- 6) During the class hours the class room doors shall not be locked from inside to outside.
- 7) As per Honorable supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the fire safety day on 14th of every year by conducting fire safety drills with co-ordinate with fire service department.

Hence this "Fire Safety recommendation" is issued to Low rise Educational Building "Sri Vidyasagara Higher Primary School" Dis No: 29120512102 Located at 21st Ward, Behind Kalika Temple. Kampli, Kampli Taluk, Ballari District subject to strict adherence of the conditions as laid down in this Recommendations and to check the portable fire extinguisher and to conduct drills periodically and the Management must not extend the height of the building beyond 15.0 meters. Subject to condition and compliance of the above recommendations in column-4 of serial-B within 3 months and compliance to undersigned.

The "Fire Advice Certificate" is valid for only one year from the date of issue.

Date- 13-08-2026
Place- Ballari.

Yours faithfully,

[Signature]
13/08/26
District Fire Officer

Karnataka State Fire and Emergency Service
Ballari District, Ballari.

5 | Page

PRINCIPAL

Sri Vidyasagara Higher Primary School
(Sri Navabharatha Vidyavardhaka Sangha(R))
21st Ward, Ballari Road,
KAMPLI-583132. Ballari (Dist)

SECRETARY

Sri Navabharatha Vidyavardhaka Sangha(R)
(Sri Vidyasagara Higher Primary School)
Vinayaka Nagara, 5th Cross,
KAMPLI-583132. Ballari (Dist)

