



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK

District water quality testing laboratory Ballari

O/o Executive Engineer, Rural Drinking water supply & sanitation Division

Zilla Panchayath Premesis, Fort area, Ballari-583102

e-mail: eerdwsd.bly@gmail.com

TEST REPORT

To,
The Principal
Sri Vdyasagara Higher Primary School
21st ward Behind Kalikadevi Temple,
Ballari Road
Kampli-583132.Ballari (Dist)

Report date: 29-06-2026
Report Number: RDWSBLY/0782/2025-26
Reference: Sample Submitted by customer
Sample receipt date: 29-06-2026
Sample code BLY/26/JUN/0782
Date of Sample collection: 29-06-2026
Analysis start date: 29-06-2026
Analysis completion date: 29-06-2026
Sample collection protocol: RDWSD/WQMSP/SOP/23

Sample Particulars -Drinking water

Sample quantity: 1 Ltr

Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012	Permissible Limit IS 10500 : 2012	Protocol
Description:					
1.	pH Value @Temp 25°C	6.62	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2.	Specific Conductance, $\mu\text{S}/\text{cm}$ @ Temp 25°C	140	–	–	IS 3025 (Part-14) : 2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Colour, Hazen Units	5	5	15	IS 3025 (Part-4) :2021
5.	Turbidity, NTU	BQL	1	5	IS 3025 (Part-10) : 2023
6.	Total Dissolved Solids@ 180°C, mg/l	76	500	2000	IS 3025 (Part-16) : 2023
7.	Total Alkalinity as CaCO_3 , mg/l	15.8	200	600	IS 3025 (Part-23) : 2023
8.	Total Hardness as CaCO_3 , mg/l	40.4	200	600	IS 3025 (Part-21) : 2009
9.	Calcium as Ca, mg/l	4.85	75	200	IS 3025 (Part-40) : 2024
10.	Magnesium as Mg, mg/l	6.87	30	100	IS 3025 (Part-46) : 2023
11.	Chloride as Cl, mg/l	13.9	250	1000	IS 3025 (Part-32) : 2025
12.	Sulphate as SO_4 , mg/l	2.20	200	400	IS 3025 (Part-24/sec1) : 2022 Method B
13.	Fluoride as F, mg/l	0.11	1	1.5	APHA 24 th Edition:4500F-D
14.	Nitrate as NO_3 , mg/l	0.20	45	No relaxation	APHA 24 th Edition:4500NO ₃ -B
15.	Iron as Fe, mg/l	BQL	1	No relaxation	IS 3025 (Part-53) : 2024 Method A

Remark: The above tested sample meets the as per the specification limit of drinking water standard IS 10500:2012 RA 2018 with respect to above tested parameters.

Analysed by:
Junior Analyst: Jadeppa M

Authorized Signatory:
Technical Manager: Bheemara C T

Note: (BQL-Below Quantification limit- for Fe & Turbidity)

RDWSD/WQMSP/TeR/01

- 1) The sample drawn by the laboratory.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.

PRINCIPAL

*****END OF THE TEST REPORT*****

SECRETARY

Sri Vidyasagara Higher Primary School
(Sri Navabharatha Vidyavardhaka Sangha(R))
21st Ward, Ballari Road,
KAMPLI-583132. Ballari (Dist)

Sri Navabharatha Vidyavardhaka Sangha(R)
(Sri Vidyasagara Higher Primary School)
Vinayaka Nagara, 5th Cross,
KAMPLI-583132. Ballari (Dist)



ಕರ್ನಾಟಕ ಸರ್ಕಾರ

ಆರೋಗ್ಯ ಮತ್ತು ಕುಟುಂಬ ಕಲ್ಯಾಣ ಇಲಾಖೆ
ಸಮುದಾಯ ಆರೋಗ್ಯ ಕೇಂದ್ರ, ಕಂಪ್ಲಿ

ತಾ: ಕಂಪ್ಲಿ

Email : mophckampli@gmail.com

ಜಿಲ್ಲೆ: ಬಳ್ಳಾರಿ

ಸಂಖ್ಯೆ ಸ.ಆ.ಕೇ.ಕಂಪ್ಲಿ/2026-27

ದಿನಾಂಕ : 13/07/2026

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


This is certify that an inspection team Headed by Dr.Ravindra Kanakeri Administrative Medical Officer from Community Health Center Kampli inspected that Sri Vidyasagara Higher Primary School Kampli on 09/07/2026 and found that the Sri Vidyasagara Higher Primary School Kampli water facilities for the students and the staff members on the institution and is maintaining the Hygienic sanitation condition in the school building and the campus as per the norms prescribed by the Central / State / UT Govt.


The above certificate is valued for the period of 1 year from the date of issue


Signature Officer
Community Health Center
Kampli, Dist. Ballari

Name and Designation of MO

To,
Principal
Sri Vidyasagara Higher Primary School
21st ward Ballari Road , Kampli
Kampi-583132


PRINCIPAL
Sri Vidyasagara Higher Primary School
(Sri Navabharatha Vidyavardhaka Sangha(R))
21st Ward, Ballari Road,
KAMPLI-583132. Ballari (Dist)


SECRETARY
Sri Navabharatha Vidyavardhaka Sangha(R)
(Sri Vidyasagara Higher Primary School)
Vinayaka Nagara, 5th Cross,
KAMPLI-583132. Ballari (Dist)